

TYPE FLAT


Test report HB09 P278

TEST REPORT FOR SPECIFIC THERMAL OUTPUT
OF FLOOR HEATING CONSTRUCTION IN ACC. TO EN 1264
LOAD DISTRIBUTION LAYER: 45 MM, PIPE: 16 x 2 mm

**IGE**

Institut für
GebäudenEnergetik

Lehrstuhl für
Heiz-und
Raumluftechnik

**Universität Stuttgart**

Stuttgart, 02.04.2009

The report shall not be reproduced except in full without the written approval of the testing lab. The test results relate only to the items tested
The test laboratory is accredited in acc. to ISO/IEC 17025 by DAR.

Acceptances from certification bodies: DIN CERTCO / RAL / AFNOR / BSI / AENOR





SPECIFIC THERMAL OUTPUT TESTING IN ACC. TO EN 1264 PART. 2, FLOOR HEATING SYSTEM

1. TEST METHOD

Initial test of floor heating system

2. INSTITUT:

Institut für GebäudeEnergetik Lehrstuhl für Heiz - und Raumlufttechnik der Universität Stuttgart
 Pfaffenwaldring 35 - D-70569 Stuttgart-Vaihingen

3. CLIENT:

COMISA S.p.A. - Via Neziole, 27 - 25055 - Pisogne (Bs) - ITALY

4. MANUFACTURER:

The Client

5. SYSTEM DESCRIPTION

trademark:	SISTEMA THERMOCONCEPT FLAT					
construction:	Type A					
spacing in m:	0,050	0,100	0,150	0,200	0,250	0,300

Pipe:

material:	PE-RT / Al / PE/RT (diffusiondicht)
diameter:	0,016 m
thickness:	0,022 m
eff. heat conductivity:	0,387 W/mK

Systeme layer plate: system plate of polystyrol

heat conductivity of nubs: 0,4 W/m K

Load distribution layer:

material:	Concrete floor
thickness:	0,045 m
heat conductivity:	1,20 W/m K

6. TEST RESULTS:

Limit specific thermal output in W/m ²	100,0	97,7	94,6	90,4	83,9	76,6
Limit temperature difference in K:	13,3	15,1	16,9	18,6	19,9	20,9

7. PROCEDURE OF TESTING:

The system was tested on 1.4.2010 (program data HB09 P278.xls) by calculation method.
An additional experimentell testing is not necessary.

8. CALCULATION RESULTS:

Characteristic curves: $q = k_H \cdot \Delta\theta_H$

ADD. FLOOR COVERING	0,00	0,05	0,10	0,15	m ² K/W
Spacing T	Equivalent coefficient for heat transfer kH				
0,050 m	7,534	5,372	4,167	3,403	W/m ² K
0,100 m	6,485	4,746	3,755	3,114	W/m ² K
0,150 m	5,604	4,203	3,392	2,851	W/m ² K
0,200 m	4,862	3,731	3,066	2,610	W/m ² K
0,250 m	4,220	3,313	2,772	2,390	W/m ² K
0,300 m	3,671	2,946	2,510	2,192	W/m ² K



Prof. Dr.-Ing. M. Schmidt

Universität Stuttgart
Institut für GebäudeEnergetik
Pfaffenwaldring 35 · 70569 Stuttgart
Tel.: (+49)711 / 685 620 85
Fax: (+49)711 / 685 620 96
www.ige.uni-stuttgart.de




Dr.-Ing. Chr. Beck

SPECIFIC THERMAL OUTPUT TESTING IN ACC. TO EN 1264 PART. 2, FLOOR HEATING SYSTEM

LIMIT CURVES Spacing T = 0,050 m

$\Delta\theta_{fmax}$	FLOOR COVERING	0,00	0,05	0,10	0,15	m ² K / W
9	Limit temperature difference	13,3	18,6	24,0	29,4	K
K	Limit specific thermal output	100,0	100,0	100,0	100,0	W / m ²
15	Limit temperature difference	23,2	32,6	42,0	51,4	K
K	Limit temperature difference	175,0	175,0	175,0	175,0	




CALCULATION FACTORS	Spacing T = 0,050 m				
Resistance of floor covering	0,000	0,050	0,100	0,150	m ² K / M
Factor B	6,735	6,725	6,719	6,716	W / m ² K
Factor a _B	1,058	0,764	0,598	0,491	
Spacing factor a _T	1,230	1,188	1,156	1,134	
Spacing exponent m _T		0,333			
Covering factor a _U	1,069	1,056	1,043	1,037	
Covering exponent m _U		0,000			
Pipe factor A _D	1,013	1,013	1,012	1,011	
Pipe exponent m _D		-1,000			
Limit curve coefficient B _G		100,000			
Limit curve exponent n _G		0,000			

LIMIT CURVES Spacing T = 0,100 m

$\Delta\theta_{fmax}$	FLOOR COVERING	0,00	0,05	0,10	0,15	m ² K / W
9	Limit temperature difference	15,1	20,8	26,5	32,1	K
K	Limit specific thermal output	97,7	98,7	99,5	100,1	W / m ²
15	Limit temperature difference	26,4	36,5	46,5	56,2	K
K	Limit temperature difference	171,3	173,1	174,5	175,0	W / m ²

Spacing T = 0,100 m




CALCULATION FACTORS		Spacing T = 0,100 m			
Resistance of floor covering	0,000	0,050	0,100	0,150	m ² K / M
Factor B	6,760	6,744	6,735	6,729	W / m ² K
Factor a _B	1,058	0,764	0,598	0,491	
Spacing factor a _T	1,230	1,188	1,156	1,134	
Spacing exponent m _T		- 0,333			
Covering factor a _U	1,063	1,050	1,039	1,034	
Covering exponent m _U		0,000			
Pipe factor A _D	1,029	1,025	1,022	1,018	
Pipe exponent m _D		-1,000			
Limit curve coefficient B _G		89,300			
Limit curve exponent n _G		0,033			

LIMIT CURVES Spacing T = 0,150 m

$\Delta\theta_{fmax}$	FLOOR COVERING	0,00	0,05	0,10	0,15	m ² K / W
9	Limit temperature difference	16,9	23,0	29,1	35,1	K
K	Limit specific thermal output	94,6	96,8	98,6	100,0	W / m ²
15	Limit temperature difference	29,6	40,4	51,0	61,4	K
K	Limit temperature difference	165,9	169,9	172,9	175,0	W / m ²

Spacing T = 0,150 m




CALCULATION FACTORS		Spacing T = 0,150 m			
Resistance of floor covering	0,000	0,050	0,100	0,150	m ² K / M
Factor B	6,777	6,758	6,747	6,739	W / m ² K
Factor a _B	1,058	0,764	0,598	0,491	
Spacing factor a _T	1,230	1,188	1,156	1,134	
Spacing exponent m _T		-1,000			
Covering factor a _Ü	1,057	1,046	1,035	1,031	
Covering exponent m _Ü		0,000			
Pipe factor A _D	1,040	1,034	1,029	1,024	
Pipe exponent m _D		-1,000			
Limit curve coefficient B _G		76,300			
Limit curve exponent n _G		0,076			

LIMIT CURVES Spacing T = 0,200 m

$\Delta\theta_{fmax}$	FLOOR COVERING	0,00	0,05	0,10	0,15	m ² K / W
9	Limit temperature difference	18,6	25,1	31,5	37,8	K
K	Limit specific thermal output	90,4	93,8	96,4	98,6	W / m ²
15	Limit temperature difference	32,6	44,1	55,2	66,3	K
K	Limit temperature difference	158,6	164,6	169,2	173,0	W / m ²

Spacing T = 0,200 m




CALCULATION FACTORS		Spacing T = 0,200 m			
Resistance of floor covering	0,000	0,050	0,100	0,150	m ² K / M
Factor B	6,790	6,769	6,757	6,748	W / m ² K
Factor a _B	1,058	0,764	0,598	0,491	
Spacing factor a _T	1,230	1,188	1,156	1,134	
Spacing exponent m _T		- 1,667			
Covering factor a _U	1,051	1,041	1,032	1,028	
Covering exponent m _U		0,000			
Pipe factor A _D	1,046	1,040	1,035	1,030	
Pipe exponent m _D		-1,000			
Limit curve coefficient B _G		63,100			
Limit curve exponent n _G		0,123			

LIMIT CURVES Spacing T = 0,250 m

$\Delta\theta_{fmax}$	FLOOR COVERING	0,00	0,05	0,10	0,15	m ² K / W
9	Limit temperature difference	19,9	26,6	33,1	39,6	K
K	Limit specific thermal output	83,9	88,3	91,6	94,5	W / m ²
15	Limit temperature difference	34,9	46,7	58,0	69,4	K
K	Limit temperature difference	147,1	154,8	160,7	165,8	W / m ²

Spacing T = 0,250 m




CALCULATION FACTORS		Spacing T = 0,250 m			
Resistance of floor covering	0,000	0,050	0,100	0,150	m ² K / M
Factor B	6,797	6,776	6,763	6,755	W / m ² K
Factor a _B	1,058	0,764	0,598	0,491	
Spacing factor a _T	1,230	1,188	1,156	1,134	
Spacing exponent m _T		-2,333			
Covering factor a _Ü	1,045	1,035	1,028	1,024	
Covering exponent m _Ü		0,000			
Pipe factor A _D	1,051	1,046	1,041	1,035	
Pipe exponent m _D		-1,000			
Limit curve coefficient B _G		49,887			
Limit curve exponent n _G		0,174			

LIMIT CURVES Spacing T = 0,300 m

$\Delta\theta_{fmax}$	FLOOR COVERING	0,00	0,05	0,10	0,15	m ² K / W
9	Limit temperature difference	20,9	27,9	34,5	41,3	K
K	Limit specific thermal output	76,6	82,3	86,7	90,6	W / m ²
15	Limit temperature difference	36,6	49,0	60,6	70,0*	K
K	Limit temperature difference	134,4	144,4	152,1	153,4**	W / m ²


* Specific thermal output with the limits of max temperature difference | ** Max temperature difference for the pipe in K

Spacing T = 0,300 m



CALCULATION FACTORS		Spacing T = 0,300 m			
Resistance of floor covering	0,000	0,050	0,100	0,150	m ² K / M
Factor B	6,802	6,781	6,769	6,761	W / m ² K
Factor a _B	1,058	0,764	0,598	0,491	
Spacing factor a _T	1,230	1,188	1,156	1,134	
Spacing exponent m _T		-3,000			
Covering factor a _U	1,040	1,031	1,024	1,021	
Covering exponent m _U		0,000			
Pipe factor A _D	1,053	1,049	1,044	1,039	
Pipe exponent m _D		-1,000			
Limit curve coefficient B _G		36,400			
Limit curve exponent n _G		0,245			

9. CONSTRUCTION DRAWING OF TEST SAMPLE:



10. PICTURE OF TEST AREA:

The test area was built on 25.3.2009 in the Institut. The used material was sended directly by the client. The construction is equal to the nominal construction of the drawing and the technical documents.

11. CONFORMITY OF THE TECHNICAL DOCUMENTS

The system is type A of DIN 18560 part. 2.
The sketch on the tecnical documents are in acc. to EN 1264 part. 4.
The official technical documents should be sended to the Institut within 6 months.



TYPE TECNO

Test report H.0904.P.613.COM

TEST REPORT FOR SPECIFIC THERMAL OUTPUT
OF FLOOR HEATING CONSTRUCTION IN ACC. TO EN 1264
LOAD DISTRIBUTION LAYER: 45 MM, PIPE: 16 x 2 mm




IGE

Institut für
GebäudenEnergetik

Lehrstuhl für
Heiz-und
Raumluftechnik



Universität Stuttgart



Stuttgart, 30.04.2009

The report shall not be reproduced except in full without the written approval of the testing lab. The test results relate only to the items tested
The test laboratory is accredited in acc. to ISO/IEC 17025 by DAR.
Acceptances from certification bodies: DIN CERTCO / RAL / AFNOR / BSI / AENOR





SPECIFIC THERMAL OUTPUT TESTING IN ACC. TO EN 1264 PART. 2, FLOOR HEATING SYSTEM

1. DECEIPTION OF THE TEST METHOD:

The heating output of the looked floor system can be determined to EN 1264 part. 2.

In part. 5 of EN 1264 instructions are given which changes are to be expcted in the output (heating case and chilled case), if the arrangement of the space surfaces is changed. Thus the arrangement on the ground is, e.g., in the chilled case the case with the lowest output values, while in the heating case the arrangement on the ground proves the highest values.

2. TEST RESULTS:

2.1 PROCEDURE OF TESTING:

The standard specific thermal output the heating case is calculated to EN 1264 for 4 standard layers (R_1 to R_4):

$R_{\lambda} = 0,0; 0,05; 0,1$ and $0,15 \text{ m}^2 \text{ K/W}$

These theoretical values of the resistance cover the really seeming floor covering to a great extent, so that for the later use with these values or interpolations the system can be laid out.

2.2 RESULTS OF HEATING CASE IN ACC. TO EN 1264 PART. 2:

Characteristic curves:

$$q = k_H \cdot \Delta\theta_H$$

ADD. FLOOR COVERING	0,00	0,05	0,10	0,15	$\text{m}^2 \text{ K/W}$
Spacing T	Equivalent coefficient for heat transfer k_H				
0,050 m	7,534	5,372	4,167	3,403	$\text{W/m}^2 \text{ K}$
0,100 m	6,485	4,746	3,755	3,114	$\text{W/m}^2 \text{ K}$
0,150 m	5,604	4,203	3,392	2,851	$\text{W/m}^2 \text{ K}$
0,200 m	4,862	3,731	3,066	2,610	$\text{W/m}^2 \text{ K}$
0,250 m	4,220	3,313	2,772	2,390	$\text{W/m}^2 \text{ K}$
0,300 m	3,671	2,946	2,510	2,192	$\text{W/m}^2 \text{ K}$



2.3 RESULTS OF CHILLED CASE IN ACC. TO EN 1264 PART. 5:

The results for the floor heating system in acc. to EN 1264 part. 2 has to be transmitted by calculation method in acc. to EN 1264 part. 5

ADD. FLOOR COVERING	α (W/m ² K)	$\Delta R_{\mu} = 1/\alpha - 1/10,8$ (m ² K/W)
Spacing T	Equivalent coefficient for heat transfer k_H	
Floor	10,8	0,0000
Floor	6,5	0,0613
Wall	8,0	0,0324
Wall	8,0	0,0324
Ceiling	6,5	0,0613
Ceiling	10,8	0,0000

3 CHARACTERISTIC CURVES FOR THE CASE OF CHILLED FLOOR

The cooling output of a floor system is reduced with the otherwise same conditions compared with the output of an under-floor heating system. A cause for this are the changed conditions on the heat transfer by convection on the surface of the floor. From part 5 on EN 1264 the respective heat transfer coefficients are known.

For the looked floor type THERMOCONCEPT STANDARD the following output values arise.

$$q = k_H \cdot \Delta\theta_H \quad \text{with} \quad \Delta\theta \text{ Temperature difference}$$

RA	0,05	0,10	0,15	0,20	0,25	0,30
K_{H1}	5,036	4,496	4,018	3,594	3,214	2,878
K_{H2}	3,964	3,596	3,265	2,964	2,691	2,446
K_{H3}	3,268	2,996	2,749	2,522	2,314	2,127
K_{H4}	2,780	2,568	2,374	2,194	2,030	1,882

Coefficient s of the characteristic curves for the different standard layers as a function of the pipe distance RA

Prof. Dr.-Ing. M. Schmidt

Universität Stuttgart
Institut für GebäudeEnergetik
Pfaffenwaldring 35 · 70569 Stuttgart
Tel.: (+49)711 / 685 620 85
Fax: (+49)711 / 685 620 96
www.ige.uni-stuttgart.de

Dr.-Ing. Chr. Beck

The figures 1 to 6 show this connection again in graphic form.




Figure 1: cooling output in dependence of the temperature distance room - water for pipe distance RA **50 mm**




Figure 2: cooling output in dependence of the temperature distance room - water for pipe distance RA **100 mm**




Figure 3: cooling output in dependence of the temperature distance room - water for pipe distance RA 150 mm




Figure 4: cooling output in dependence of the temperature distance room - water for pipe distance RA 200 mm




Figure 5: cooling output in dependence of the temperature distance room - water for pipe distance RA 250 mm




Figure 6: cooling output in dependence of the temperature distance room - water for pipe distance RA 300 mm