

# TYPE WET EPS

## Test report HB12 P375

TEST REPORT FOR SPECIFIC THERMAL OUTPUT  
OF FLOOR HEATING CONSTRUCTION IN ACC. TO EN 1264  
LOAD DISTRIBUTION LAYER: 12 mm, PIPE: 12 x 1.3 mm

**IGE**

Institut für  
GebäudenEnergetik

Lehrstuhl für  
Heiz-und  
Raumluftechnik

**Universität Stuttgart**

Stuttgart, 02.04.2009

The report shall not be reproduced except in full without the written approval of the testing lab. The test results relate only to the items tested.  
The test laboratory is accredited in acc. to ISO/IEC 17025 by DAR.

Acceptances from certification bodies: DIN CERTCO / RAL / AFNOR / BSI / AENOR





## SPECIFIC THERMAL OUTPUT TESTING IN ACC. TO EN 1264 PART. 2, FLOOR HEATING SYSTEM

### 1. TEST METHOD

Initial test of floor heating system

### 2. INSTITUT:

Institut für GebäudeEnergetik Lehrstuhl für Heiz - und Raumlufttechnik der Universität Stuttgart  
 Pfaffenwaldring 35 - D-70569 Stuttgart-Vaihingen

### 3. CLIENT:

COMISA S.p.A. - Via Neziole, 27 - 25055 - Pisogne (Bs) - ITALY

### 4. MANUFACTURER:

The Client

### 5. SYSTEM DESCRIPTION

trademark: SISTEMA WET EPS  
 construction: Type A  
 spacing in m: 0,100 0,200 0,300

#### Pipe:

material: JANOlén 12 x 1.3mm PE-RT Type 1 (producer: Jansen Switzerland)  
 diameter: 0,012 m  
 thickness: 0,0013 m  
 eff. heat conductivity: 0,35 W/mK

**Systeme layer plate:** plate within nubs of polystyrol

heat conductivity of nubs: 0,4 W/m K  
 volume of nubs in %: 51,25 49,47 48,91

#### Load distribution layer:

material: Concrete floor  
 thickness: 0,012 m  
 heat conductivity: 1,20 W/m K  
 effective heat conductivity in W/mK 0,61 0,63 0,63

## 6. TEST RESULTS:

|                                                   |      |       |       |
|---------------------------------------------------|------|-------|-------|
| Limit specific thermal output in W/m <sup>2</sup> | 73,0 | 66,0  | 51,3  |
| Limit temperature difference in K:                | 9,0  | 49,47 | 48,91 |

## 7. PROCEDURE OF TESTING:

The system was tested on 17.7.2012 (program data HB09 P278.xls) by calculation method.  
 An additional experimentell testing is not necessary.

## 8. CALCULATION RESULTS:

Characteristic curves:  $q = k_H \cdot \Delta\theta_H$

| ADD. FLOOR COVERING | 0,00                                        | 0,05  | 0,10  | 0,15  | m <sup>2</sup> K/W |
|---------------------|---------------------------------------------|-------|-------|-------|--------------------|
| Spacing T           | Equivalent coefficient for heat transfer kH |       |       |       |                    |
| 0,100 m             | 8,143                                       | 5,650 | 4,290 | 3,491 | W/m <sup>2</sup> K |
| 0,200 m             | 4,592                                       | 3,603 | 2,966 | 2,552 | W/m <sup>2</sup> K |
| 0,300 m             | 3,353                                       | 2,758 | 2,374 | 2,101 | W/m <sup>2</sup> K |



Prof. Dr.-Ing. M. Schmidt

Universität Stuttgart  
**Institut für GebäudeEnergetik**  
 Pfaffenwaldring 35 · 70569 Stuttgart  
 Tel.: (+49)711 / 685 620 85  
 Fax: (+49)711 / 685 620 96  
[www.ige.uni-stuttgart.de](http://www.ige.uni-stuttgart.de)




Dr.-Ing. Chr. Beck

## SPECIFIC THERMAL OUTPUT TESTING IN ACC. TO EN 1264 PART. 2, FLOOR HEATING SYSTEM

### LIMIT CURVES Spacing $T = 0,100 \text{ m}$

| $\Delta\theta_{fmax}$ | FLOOR COVERING                | 0,00        | 0,05  | 0,10  | 0,15  | $\text{m}^2 \text{ K} / \text{W}$ |
|-----------------------|-------------------------------|-------------|-------|-------|-------|-----------------------------------|
| 9                     | Limit temperature difference  | <b>9,0</b>  | 13,2  | 17,6  | 21,8  | K                                 |
| K                     | Limit specific thermal output | <b>73,0</b> | 74,3  | 75,3  | 76,0  | $\text{W} / \text{m}^2$           |
| 15                    | Limit temperature difference  | 15,7        | 23,1  | 30,8  | 38,2  | K                                 |
| K                     | Limit temperature difference  | 128,1       | 130,3 | 132,1 | 133,4 | $\text{W} / \text{m}^2$           |




| CALCULATION FACTORS           |       | Spacing $T = 0,050 \text{ m}$ |       |       |                                   |
|-------------------------------|-------|-------------------------------|-------|-------|-----------------------------------|
| Resistance of floor covering  | 0,000 | 0,050                         | 0,100 | 0,150 | $\text{m}^2 \text{ K} / \text{M}$ |
| Factor B                      | 7,140 | 7,005                         | 6,932 | 6,889 | $\text{W} / \text{m}^2 \text{ K}$ |
| Factor $a_B$                  | 1,058 | 0,764                         | 0,598 | 0,491 |                                   |
| Spacing factor $a_T$          | 1,230 | 1,188                         | 1,156 | 1,134 |                                   |
| Spacing exponent $m_T$        |       | - 0,333                       |       |       |                                   |
| Covering factor $a_U$         | 1,063 | 1,050                         | 1,039 | 1,034 |                                   |
| Covering exponent $m_U$       |       | 0,000                         |       |       |                                   |
| Pipe factor $A_D$             | 1,029 | 1,025                         | 1,022 | 1,018 |                                   |
| Pipe exponent $m_D$           |       | - 2,000                       |       |       |                                   |
| Limit curve coefficient $B_G$ |       | 66,000                        |       |       |                                   |
| Limit curve exponent $n_G$    |       | 0,046                         |       |       |                                   |

## LIMIT CURVES Spacing T = 0,200 m

| $\Delta\theta_{fmax}$ | FLOOR COVERING                | 0,00        | 0,05  | 0,10  | 0,15  | m <sup>2</sup> K / W |
|-----------------------|-------------------------------|-------------|-------|-------|-------|----------------------|
| 9                     | Limit temperature difference  | <b>14,4</b> | 19,0  | 23,8  | 28,3  | K                    |
| K                     | Limit specific thermal output | <b>66,0</b> | 68,5  | 70,5  | 72,1  | W / m <sup>2</sup>   |
| 15                    | Limit temperature difference  | 25,2        | 33,3  | 41,7  | 49,6  | K                    |
| K                     | Limit temperature difference  | 115,8       | 120,1 | 123,6 | 126,4 | W / m <sup>2</sup>   |

### Spacing T = 0,200 m




| CALCULATION FACTORS                    |       | Spacing T = 0,100 m |       |       |                      |
|----------------------------------------|-------|---------------------|-------|-------|----------------------|
| Resistance of floor covering           | 0,000 | 0,050               | 0,100 | 0,150 | m <sup>2</sup> K / M |
| Factor B                               | 7,196 | 7,089               | 7,021 | 6,976 | W / m <sup>2</sup> K |
| Factor a <sub>B</sub>                  | 0,837 | 0,642               | 0,520 | 0,438 |                      |
| Spacing factor a <sub>T</sub>          | 1,230 | 1,188               | 1,156 | 1,134 |                      |
| Spacing exponent m <sub>T</sub>        |       | - 1,667             |       |       |                      |
| Covering factor a <sub>Ü</sub>         | 1,051 | 1,041               | 1,032 | 1,028 |                      |
| Covering exponent m <sub>Ü</sub>       |       | 3,300               |       |       |                      |
| Pipe factor A <sub>D</sub>             | 1,046 | 1,040               | 1,035 | 1,030 |                      |
| Pipe exponent m <sub>D</sub>           |       | - 2,000             |       |       |                      |
| Limit curve coefficient B <sub>G</sub> |       | 46,670              |       |       |                      |
| Limit curve exponent n <sub>G</sub>    |       | 0,130               |       |       |                      |

## LIMIT CURVES Spacing T = 0,300 m


| $\Delta\theta_{fmax}$ | FLOOR COVERING                | 0,00        | 0,05 | 0,10  | 0,15  | m <sup>2</sup> K / W |
|-----------------------|-------------------------------|-------------|------|-------|-------|----------------------|
| 9                     | Limit temperature difference  | <b>15,3</b> | 19,9 | 24,3  | 28,6  | K                    |
| K                     | Limit specific thermal output | <b>51,3</b> | 54,8 | 57,7  | 60,1  | W / m <sup>2</sup>   |
| 15                    | Limit temperature difference  | 26,8        | 34,9 | 42,6  | 50,2  | K                    |
| K                     | Limit temperature difference  | 90,0        | 96,2 | 101,2 | 105,5 | W / m <sup>2</sup>   |

### Spacing T = 0,300 m



| CALCULATION FACTORS                    |       | Spacing T = 0,150 m |       |       |                      |
|----------------------------------------|-------|---------------------|-------|-------|----------------------|
| Resistance of floor covering           | 0,000 | 0,050               | 0,100 | 0,150 | m <sup>2</sup> K / M |
| Factor B                               | 7,244 | 7,147               | 7,085 | 7,041 | W / m <sup>2</sup> K |
| Factor a <sub>B</sub>                  | 0,840 | 0,644               | 0,522 | 0,439 |                      |
| Spacing factor a <sub>T</sub>          | 1,230 | 1,188               | 1,156 | 1,134 |                      |
| Spacing exponent m <sub>T</sub>        |       | -3,000              |       |       |                      |
| Covering factor a <sub>Ü</sub>         | 1,040 | 1,031               | 1,024 | 1,021 |                      |
| Covering exponent m <sub>Ü</sub>       |       | 3,300               |       |       |                      |
| Pipe factor A <sub>D</sub>             | 1,053 | 1,049               | 1,044 | 1,039 |                      |
| Pipe exponent m <sub>D</sub>           |       | -2,000              |       |       |                      |
| Limit curve coefficient B <sub>G</sub> |       | 25,740              |       |       |                      |
| Limit curve exponent n <sub>G</sub>    |       | 0,253               |       |       |                      |

## 9. CONSTRUCTION DRAWING OF TEST SAMPLE:



## 10. PICTURE OF TEST AREA:

The test area was built on 25.3.2009 in the Institut. The used material was sendet directly by the client. The construction is equal to the nominal construction of the drawing and the technical documents.

## 11. CONFORMITY OF THE TECHNICAL DOCUMENTS

The system is type A of DIN 18560 part. 2.  
The sketch on the technical documents are in acc. to EN 1264 part. 4.  
The official technical documents should be sendet to the Institut within 6 months.



# TYPE WET EPS

## Test report L.1207.P.921.COM

TEST REPORT FOR SPECIFIC THERMAL OUTPUT  
OF FLOOR HEATING CONSTRUCTION IN ACC. TO EN 1264  
LOAD DISTRIBUTION LAYER: 12 mm, PIPE: 12 x 1.3 mm

**IGE**

Institut für  
GebäudenEnergetik

Lehrstuhl für  
Heiz-und  
Raumluftechnik

**Universität Stuttgart**

Stuttgart, 30.04.2009

The report shall not be reproduced except in full without the written approval of the testing lab. The test results relate only to the items tested.  
The test laboratory is accredited in acc. to ISO/IEC 17025 by DAR.

Acceptances from certification bodies: DIN CERTCO / RAL / AFNOR / BSI / AENOR



**TEST METHODE:**

The currently valid versions of the following documents form the basis for inspection and certification:

DIN EN 1264-2: Prüfverfahren (1/2009)

DIN EN 1264-4: Installation (11/2009)

DIN EN 1264-5: Berechnungsverfahren (1/2009)

Zertifizierungsprogramm DIN CERTCO: (Raumflächen-integrierte Heiz- und Kühlsysteme mit Wasserdurchströmung“)

**TEST ITEM:**

Type WET EPS, load distribution layer: 12 mm

**START - END OF TESTS:**

23.7.2012 - 23.07.2012

**MANUFACTURER:**

The Client

**TRADEMARK:**

WET EPS

**SYSTEM DESCRIPTION:**

Nassverlegesystem mit Kundtoff-Rohren (siehe Abbildungen im Anhang dieses Berichtes)

**SYSTEM CONSTRUCTION:**

Type A in acc. to DIN EN 1264

**DISTIBUTION LAYER:**

screed: 12 mm

**PIPE:**

JANOlén 12x1.3 mm PE-RT Typ 1 (producer: Jansen Switzerland)

**INSERTS:**

-

**PIPE FIXATION:**

Pipe embedded in the system place (slot)

**SPACING:**

100 mm, 200mm, 300 mm

**TEST SAMPLE:**

testing by calculation methode

**DATE OF RECEIPT:**

18.6.2012



## SPECIFIC THERMAL OUTPUT TESTING IN ACC. TO EN 1264 PART. 2, FLOOR HEATING SYSTEM

### 1. DECEIPTION OF THE TEST METHOD:

The heating output of the looked floor system can be determined to EN 1264 part. 2.

In part. 5 of EN 1264 instructions are given which changes are to be expcted in the output (heating case and chilled case), if the arrangement of the space surfaces is changed. Thus the arrangement on the ground is, e.g., in the chilled case the case with the lowest output values, while in the heating case the arrangement on the ground proves the highest values.

### 2. TEST RESULTS:

#### 2.1 PROCEDURE OF TESTING:

The standard specific thermal output the heating case is calculated to EN 1264 for 4 standard layers ( $R_1$  to  $R_4$ ):

$R_{\lambda} = 0,0; 0,05; 0,1$  and  $0,15 \text{ m}^2 \text{ K/W}$

These theoretical values of the resistance cover the really seeming floor covering to a great extent, so that for the later use with these values or interpolations the system can be laid out.

#### 2.2 RESULTS OF HEATING CASE IN ACC. TO EN 1264 PART. 2:

Characteristic curves:

$$q = k_H \cdot \Delta\theta_H$$

| ADD. FLOOR<br>COVERING | 0,00                                           | 0,05  | 0,10  | 0,15  | $\text{m}^2 \text{ K/W}$ |
|------------------------|------------------------------------------------|-------|-------|-------|--------------------------|
| Spacing T              | Equivalent coefficient for heat transfer $k_H$ |       |       |       |                          |
| 0,100 m                | 8,143                                          | 5,650 | 4,290 | 3,491 | $\text{W/m}^2 \text{ K}$ |
| 0,200 m                | 4,592                                          | 3,603 | 2,966 | 2,552 | $\text{W/m}^2 \text{ K}$ |
| 0,300 m                | 3,353                                          | 2,758 | 2,374 | 2,101 | $\text{W/m}^2 \text{ K}$ |

### 2.3 RESULTS OF CHILLED CASE IN ACC. TO EN 1264 PART. 5:

The results for the floor heating system in acc. to EN 1264 part. 2 has to be transmitted by calculation method in acc. to EN 1264 part. 5

| ADD. FLOOR COVERING | $\alpha$ (W/m <sup>2</sup> K)                  | $\Delta R_{\mu} = 1/\alpha - 1/10,8$ (m <sup>2</sup> K/W) |
|---------------------|------------------------------------------------|-----------------------------------------------------------|
| Spacing T           | Equivalent coefficient for heat transfer $k_H$ |                                                           |
| Floor               | 10,8                                           | 0,000 0                                                   |
| Floor               | 6,5                                            | 0,061 0                                                   |
| Wall                | 8,0                                            | 0,032 4                                                   |
| Wall                | 8,0                                            | 0,032 4                                                   |
| Ceiling             | 6,5                                            | 0,061 3                                                   |
| Ceiling             | 10,8                                           | 0,000 0                                                   |

### 3 CHARACTERISTIC CURVES FOR THE CASE OF CHILLED FLOOR

The cooling output of a floor system is reduced with the otherwise same conditions compared with the output of an under-floor heating system. A cause for this are the changed conditions on the heat transfer by convection on the surface of the floor. From part 5 on EN 1264 the respective heat transfer coefficients are known.

For the looked floor type WET EPS (covering: 12mm, pipe: PE-RT, 12x1.3mm) the following output values arise.

$q = k_H \cdot \Delta\theta_H$  with  $\Delta\theta$  Temperature difference

| RA       | 0,10  | 0,20  | 030   |
|----------|-------|-------|-------|
| $K_{H1}$ | 5,272 | 3,461 | 2,696 |
| $K_{H2}$ | 4,095 | 2,882 | 2,325 |
| $K_{H3}$ | 3,347 | 2,469 | 2,043 |
| $K_{H4}$ | 2,830 | 2,159 | 1,823 |

Coefficient  $s$  of the characteristic curves for the different standard layers as a function of the pipe distance RA




Prof. Dr.-Ing. M. Schmidt

Universität Stuttgart  
**Institut für GebäudeEnergetik**  
 Pfaffenwaldring 35 · 70569 Stuttgart  
 Tel.: (+49)711 / 685 620 85  
 Fax: (+49)711 / 685 620 96  
[www.ige.uni-stuttgart.de](http://www.ige.uni-stuttgart.de)




Dr.-Ing. Chr. Beck


The figures 1 to 3 show this connection again in graphic form.



**Figure 1:** cooling output in dependence of the temperature distance room - water for pipe distance RA **100 mm**



**Figure 2:** cooling output in dependence of the temperature distance room - water for pipe distance RA **200 mm**



**Figure 3:** cooling output in dependence of the temperature distance room - water for pipe distance RA **300 mm**

**COMISA**



**WWW.COMISA.IT**